

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Crete is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact: JESSE YAGER, 402-826-4312.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at: <http://www.epa.gov/safewater/lead>.

For more information regarding this report, or to request a hard copy, contact:

Tom Ourada
City Administrator
Department of Public Works
243 East 13th Street
Crete, Nebraska 68333
(402) 826-4312
tom.ourada@crete.ne.gov



ANNUAL WATER QUALITY REPORT
for the period of
January 1, 2025 to December 31, 2025



This report is intended to provide you with important information about your drinking water and the efforts made by the City of Crete water system to provide safe drinking water.

If you would like to observe the decision-making processes that affect drinking water quality, please attend the regularly scheduled meeting of the Crete City Council. If you would like to participate in the process, please contact Nancy Tellez, City Clerk, at (402) 826-4313 to arrange to be placed on the agenda of the next regularly scheduled meeting of the Crete City Council.

This report will not be mailed but copies of this report are available to the public upon request. This report is also available on the City of Crete web-site at <http://www.crete.ne.gov>

Para Clientes Que Hablan Español:

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

2025 ANNUAL WATER QUALITY REPORT - CITY OF CRETE

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

SOURCE WATER ASSESSMENT AVAILABILITY

The Nebraska Department of Water, Environment and Energy (DWEE) has completed the Source Water Assessment. Included in the assessment are a Wellhead Protection Area map, potential contaminant source inventory, and source water protection information. To view the Source Water Assessment or for more information please contact the person named on the back cover of this report or DWEE at (402) 471-3376 or (402) 471-9249 or go to <http://dee.ne.gov>.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

SOURCES OF DRINKING WATER

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

The source of drinking water used by the City of Crete is groundwater.

CONTAMINANTS THAT MAY BE PRESENT IN SOURCE WATER INCLUDE:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

DRINKING WATER HEALTH NOTES

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

THE CITY OF CRETE IS REQUIRED TO TEST FOR THE FOLLOWING CONTAMINANTS:

Coliform Bacteria, Antimony, Arsenic, Asbestos, Barium, Beryllium, Cadmium, Chromium, Copper, Cyanide, Fluoride, Lead, Mercury, Nickel, Nitrate, Nitrite, Selenium, Sodium, Thallium, Alachlor, Atrazine, Benzo(a)pyrene, Carbofuran, Chlordane, Dalapon, Di(2-ethylhexyl)adipate, Dibromochloropropane, Dinoseb, Di(2-ethylhexyl)-phthalate, Diquat, 2,4-D, Endothal, Endrin, Ethylene dibromide, Glyphosate, Heptachlor, Heptachlor epoxide, Hexachlorobenzene, Hexachlorocyclopentadiene, Lindane, Methoxychlor, Oxamyl (Vydate), Pentachlorophenol, Picloram, Polychlorinated biphenyls, Simazine, Toxaphene, Dioxin, Silvex, Benzene, Carbon Tetrachloride, o-Dichloro-benzene, Para-Dichlorobenzene, 1, 2-Dichloroethane, 1,1-Dichloroethylene, Cis-1, 2,-Dichloroethylene, Trans-1,2-Dichloroethylene, Dichloromethane, 1,2-Dichloropropane, Ethylbenzene, Monochlorobenzene, 1,2,4-Trichloro-benzene, 1,1,1-Trichloroethane, 1,1,2-Trichloroethane, Trichloroethylene, Vinyl Chloride, Styrene, Tetrachloroethylene, Toluene, Xylenes (total), Gross Alpha (minus Uranium & Radium 226), Radium 226 plus Radium 228, Sulfate, Chloroform, Bromodichloromethane, Chlorodibromomethane, Bromoform, Chlorobenzene, m-Dichlorobenzene, 1,1-Dichloropropene, 1,1-Dichloroethane, 1,1,2,2-Tetrachloroethane, 1,2-Dichloropropane, Chloromethane, Bromomethane, 1,2,3-Trichloropropane, 1,1,1,2-Tetrachloroethane, Chloroethane, 2,2-Dichloropropane, o-Chlorotoluene, p-Chlorotoluene, Bromobenzene, 1,3-Dichloropropene, Aldrin, Butachlor, Carbaryl, Dicamba, Dieldrin, 3-Hydroxycarbofuran, Methomyl, Metolachlor, Metribuzin, Propachlor

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Some people who drink water containing endrin in excess of the MCL over many years could experience liver problems.

There are no additional required health effects violation notices.

HOW TO READ THE WATER QUALITY DATA TABLE:

The EPA and State Drinking Water Program establish the safe drinking water regulations that limit the amount of contaminants allowed in drinking water. The table shows the concentrations of detected substances in comparison to the regulatory limits. Substances not detected are not included in the table. The state requires monitoring of certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of this data may be older than one year.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

AL (Action Level) The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MRDL (Maximum Residual Disinfectant Level) - The highest level of a disinfectant allowed in drinking water.

N/A- Not applicable.

2025 ANNUAL WATER QUALITY REPORT CITY OF CRETE

TEST RESULTS (COLLECTED IN 2025 UNLESS NOTED)

- No Violations Occurred in the Calendar Year 2025
- There are no additional health effects notices.
- There are no additional required health effects violation notices

Microbiological	Highest No. of Positive Samples	MCL	MCLG	Likely Source of Contamination	Violations Present		
Coliform (TCR)	In the month of March, 1 sample(s) were positive	Treatment Technique Trigger	0	Naturally present in the environment	Yes		
Contaminant (Lead and Copper)	Range	Action Level (AL)	90th Percentile	# Sites Over AL	Likely Source of Contaminant		
Copper, Free 2023-2025	0.0135-1.35	1.3 ppm	0.594 ppm	1	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.		
Lead 2023-2025	0 - 3.04	15 ppb	1.57 ppb	0			
Regulated Contaminants							
Contaminant	Highest Level Detected	Range of Levels Detected	Units	MCLG	MCL	Violation	Likely Source of Contamination
*Arsenic (4/23/25)	4.7	1.8-4.7	ppb	0	10	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (7/12/2021)	0.137	0.137	ppm	2	2	No	Discharge from drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (7/12/2021)	0.275	0.275	ppm	4	4	No	Erosion of natural deposits; Water additive which promotes strong teeth; Fertilizer discharge
Nitrate-Nitrite (11/10/2025)	2.07	0-2.07	ppm	10	10	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Radiological Contaminants							
Contaminant	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination
COMBINED RADIUM (-226 & -228)	2/20/2025	2.83	0-2.83	pCi/L	5	0	Erosion of natural deposits
GROSS ALPHA, INCL. RADON & U	3/05/2025	9.64	4.38-9.64	pCi/L	15	0	Erosion of natural deposits
RADIUM-228	02/20/2025	1.06	0-1.06	pCi/L		0	Erosion of natural deposits
RADIUM-226	02/20/2025	1.77	0-1.77			0	Erosion of natural deposits
Unregulated Water Quality Data							
Contaminant	Collection Date	Highest Value	Range	Unit	Secondary MCL		
Metolachlor	5/13/2024	0.102	0-0.102	ppb			
Sulfate	11/18/2021	94.8	42.7-94.8	mg/L	250		

Units in the Table:

ND - Not detectable.

ppm: (parts per million) - One ppm corresponds to 1 gallon of concentrate in 1 million gallons of water.

mg/L: (milligrams per liter) - Equivalent to ppm

ppb: (parts per billion) - One ppb corresponds to 1 gallon of concentrate in 1 billion gallons of water.

ug/L: (micrograms per liter) - Equivalent to ppb

pCi/L: (picocuries per liter) - Radioactivity concentration unit.

RAA (Running Annual Average) An ongoing annual average calculation of data from the most recent four quarters.

LRAA (Locational Running Annual Average) An ongoing annual average calculation of data from the most recent four quarters at each sampling location

90th Percentile - Represents the highest value found out of 90% of the samples taken in a representative group. If the 90th percentile is greater than the action level, it will trigger a treatment or other requirements that a water system must follow.

TT: (Treatment Technique) - A required process intended to reduce the level of a contaminant in drinking water.

The City of Crete Lead Service Line Inventory has been prepared and can be accessed here: www.crete.ne.gov